



**Government of West Bengal**  
**Office of the Divisional Fire Officer**  
**West Bengal Fire & Emergency Services**  
**Bhangakhuti, Purba Burdwan, P.O.:- Rajbati, Pin :- 713104**

**Memo No.: FSR/0125186210300066**

**Date : 07-05-2024**

**From :**  
**Divisional Fire Officer**  
**Fire Prevention Wing ,**  
**West Bengal Fire & Emergency Services**

**To :**  
**Tarapada Dey Educational Institution**  
**Vill.Srirampur, P.O.Dakshin Srirampur, Mouza.Srirampur, JI no.135, Plot no.1943, Kh no.4593,8885, Ps.**  
**Purbasthali,Dist. Purba Burdwan.741316**

**Sub : Renewal of Fire Safety Certificate in Favour of Tarapada Dey Educational Institution**

**Memo No.: FSR/0125186210300066**

This is in reference to your AIN 211912406300000195 dated 13-Apr-2024 regarding Renewal of Fire Safety Certificate in Favour of Tarapada Dey Educational Institution.

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

**However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.**

**Recommendation:**

Renewal of Fire Safety Certificate for the occupancy of an existing G+3 Storied building in favour of Tarapada Dey Educational Institution at the premises no- Vill.Srirampur , P.S .Purbasthli, J.L 135, P.L 1943, K.H 4593,8885, Purba Bardhaman, Pin 741316. 1. Driveway Must be Free of any type of obstruction for



The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300000195

easy movement of fire appliances. 2.No parking will be allowed on the drive way. 3. A Fire control room including a closed circuit tv system will be maintained which observe all floor of the building. 4.mimumum 4no ABC (6.5 kg) and 2 no CO2 (4.5kg ) fire extinguisher shall be kept at each floor . 5. Provision of anther hose reel system conjunction with the down comer shall be made at each floor level as such that no part of the protect floor is more than 6m. 6. The employees and security staff shall be conversant with fire fighting equipment of the building and to operate in the event of fire and testing. 7.A crew of trained fire men under the experienced officer shell be maintained round the clock for safety of the building. 8.The Fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register . 9. Directional sign of escape route shall be displayed prominently. 10. Recommended standby pump to be installed 5HP instate 3.5 HP within six month. 11. No deviation change of this building without the prior permission of this department otherwise this RFSC treated as cancelled. 12. This RFSC is valid for three years and has to be renewed every three years from the date of issue of this letter.

**Valid Upto : 07-May-2027**

**Memo No.: FSR/0125186210300066**



**Divisional Fire Officer  
West Bengal Fire & Emergency Services**

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300000195